



INSTRUMENTATION DETAILS			
SENSOR	DESCRIPTION	SETTING	ACTION
S1	HIGH DISCH TEMP	2HP - 356°F	SHUTDOWN
		3HP - 445°F	
		5HP - 465°F	
		7.5HP - 465°F	
S2	PRESS TRANSDUCER	0 - 145PSI	OPERATION
S3	BACKUP PRESS SW.	CUT IN - 110PSI	BACKUP OPERATION
		CUT OUT - 135PSI	
S4	DP SENSOR	-30° C	ALARM

Revised: SMB	Date: 11/19/2019	Drawn: SMB	Date: 08/12/2019
			Scale: NTS
Description: DWG PNEU DX SCRL LAB 2-7.5HP 10BAR -40			Part Number: 4107 8570 26 DN: HOP191299 Rev: 03
Sheet 1 of 1			DO NOT SCALE THIS DOCUMENT