



- Notes:
1. SYSTEM WEIGHT: 1,206 LBS.
  2.  INDICATES LIFTING POINT.
  3.  DENOTES CENTER OF GRAVITY.

SYSTEM CONNECTIONS	
ID	DESCRIPTION
I	INLET LOCATION
D	DISCHARGE LOCATION
C	CONDENSATE DRAIN LOCATION
T	TANK DRAIN LOCATION

ELECTRICAL CONNECTION

MINIMUM CLEARANCE FOR  
MAINTENANCE & VENTILATION

CONTROL  
CABINET

INTEGRATED  
LIFTING EYES

RECEIVER BYPASS  
VALVE

INLET  
2" FLANGE


VACUUM EQUALIZE  
VALVE 1/2" FNPT

DISCHARGE  
2" FLANGE

INTAKE FILTER  
PER PUMP

TANK DRAIN  
1/2" FNPT

CONDENSATE DRAIN  
1/2" FNPT

Revised: MDB	Date: 05/23/2019	Drawn: GTM	Date: 05/13/2011
		This drawing and the information contained therein remain the property of BeaconMedaes and may not be used for other than the purpose for which it is loaned without the expressed written permission from BeaconMedaes Engineering.	
Description: GENERAL ASSEMBLY BASIC 3HP DX LUBE VAC STM 60G RECEIVER		Part Number: 4107 8531 22	
DN: BM190345		Rev: 02	
Sheet 1 of 1		DO NOT SCALE THIS DOCUMENT	