



INSTRUMENTATION DETAILS			
SENSOR	DESCRIPTION	SETTING	ACTION
S1	HIGH DISCH TEMP	10HP-465°F	SHUTDOWN
		15HP-465°F	
S2	PRESS TRANSDUCER	0-145PSI	OPERATION
S3	BACKUP PRESS SW.	CUT IN-110PSI	BACKUP OPERATION
		CUT OUT-135PSI	
S4	DP SENSOR	-30° C	ALARM

Revised: SMB	Date: 11/19/2019	Drawn: SMB	Date: 08/12/2019
		Scale: NTS	
Description: DWG PNEU HX SCL LAB 10-15HP 10BAR -40		Part Number: 4107 8570 33	
Dwg: HOP191299		Rev: 03	
Sheet 1 of 1		DO NOT SCALE THIS DOCUMENT	