



NOTES:

1. DISCHARGE CONNECTION HAS INTEGRATED FLEX HOSE DESIGN
2. SYSTEM WEIGHT: 5186 LBS
3.  INDICATES LIFTING POINTS
4.  DENOTES CENTER OF GRAVITY

SYSTEM CONNECTIONS	
ID	DESCRIPTION
D	DISCHARGE LOCATION
C	CONDENSATE DRAIN LOCATION

MINIMUM CLEARANCE FOR MAINTENANCE AND VENTILATION

ZERO LOSS
DRAIN VALVE

ETHERNET WIRING ACCESS

ALARM WIRING ACCESS

ELECTRICAL CONNECTION

Ø0.75 BOLTDOWN
(16 PLACES)

AIR RECEIVER-
240 GALLON

DUAL DESICCANT-
-40°C AIR DRYERS

DEW POINT-
TRANSDUCER

DISCHARGE-
1-1/2" NPT FEMALE

D 12.37

INTEGRATED
LIFTING EYES

SINGLE POINT CONDENSATE
DRAIN CONNECTION
1/2" NPT (FEMALE)

C 18.49



LIQUID LEVEL SIGHT GLASS
W/ FLOAT INDICATOR

CONTROL PANEL

INTAKE FILTER
PER COMPRESSOR

—AFTERCOOLER

HEAVY-DUTY
4-POINT ISOLATION
(SEISMIC OPTIONAL)

Revised:	MD	Date:	4/10/2020	Drawn:	SMB	Date:	7/22/2019
 BEACON MEDICS		This drawing and the information contained thereon remain the property of BeaconMedics and may not be used for other than the purpose for which it is loaned without the expressed written permission from BeaconMedics Engineering.				Scale: NTS	
Description:		Part Number:					
DWG GEN ASM HX SCRL LAB 10HP		4107 8570 14					
10BAR 240G -40		DN: HOP200057 Sheet 1 of 1					
				Rev: 02 DO NOT SCALE THIS DRAWING			