



Notes:

1. DISCHARGE MUFFLERS WILL BE SHIPPED LOOSE.
2. WEIGHT OF DUPLEX MODULE W/ PANEL: 2,312 LBS
WEIGHT OF DUPLEX MODULE W/O PANEL: 2,144 LBS
240G TANK WEIGHT: 733 LBS
3.  INDICATES LIFTING POINT.
4.  DENOTES CENTER OF GRAVITY.

SYSTEM CONNECTIONS	
ID	DESCRIPTION
I	INLET LOCATION
D	DISCHARGE LOCATION
C	CONDENSATE DRAIN LOCATION
T	TANK DRAIN LOCATION

ELECTRICAL CONNECTION

MINIMUM CLEARANCE FOR MAINTENANCE & VENTILATION

Ø0.75
BOLTDOWN
(8 PLACES)

REMOVE INTAKE MANIFOLD BEFORE LIFTING
(2 PLACES)

REMOVE JUNCTION BOX BEFORE LIFTING
(LOCATED ON THIS MODULE ONLY)

RECEIVER BYPASS VALVE

HOSPITAL CONN
4" FLANGE

MANUAL DRAIN CONN
1/2" NPT (FEMALE)

0.69 X 1.06 SLOT
ON 26.00 DIA B.C.
EQUALLY SPACED
(4 PLACES)

240 GAL VACUUM RECEIVER
4" FLANGED CONNECTIONS
(SCALE 1:10)

CONTROL CABINET

INLET
3" FLANGE
(2 PLACES)

HEPA INTAKE FILTER
PER PUMP

DISCHARGE
3" FLANGE
(2 PLACES)

JUNCTION BOX
FOR CONTROL
WIRING

MANUAL
CONDENSATE
DRAIN, TYP

INTEGRATED
LIFTING EYES

BIOHAZARD DRAIN FLASK
PER PUMP