



Notes:

- 1. DISCHARGE MUFFLERS WILL BE SHIPPED LOOSE.
- 2. SYSTEM WEIGHT: 8,143 LBS.
(INCLUDES FUTURE EXPANSION PUMP)
- 3. ☒ INDICATES LIFTING POINT.
- 4. ● DENOTES CENTER OF GRAVITY.
(INCLUDES FUTURE EXPANSION PUMP)

SYSTEM CONNECTIONS	
ID	DESCRIPTION
I	INLET LOCATION
D	DISCHARGE LOCATION
T	TANK DRAIN LOCATION
C	CONDENSATE DRAIN LOCATION

Ø0.75 BOLTDOWN
(16 PLACES)

FUTURE EXPANSION PUMP

MINIMUM CLEARANCE FOR
MAINTENANCE & VENTILATION

ELECTRICAL
CONNECTION

INTAKE ISOLATION
VALVE FOR FUTURE
EXPANSION PUMP

RECEIVER BYPASS
VALVE

240 GALLON
RECEIVER

CONTROL CABINET

HEPA INTAKE FILTER
PER PUMP

DISCHARGE
3" FLANGE
(3 PLACES)

INLET
4" FLANGE

BIOHAZARD DRAIN
FLASK PER PUMP

MANUAL DRAIN
1/2" FNPT

INTEGRATED
LIFTING EYES

MANUAL
CONDENSATE
DRAIN,TYP

Revised: LHG	Date: 12/19/2023	Drawn: JWO	Date: 1/13/2014
This drawing and the information contained therein remain the property of BeaconMedaes and may not be used for other than the purpose for which it is loaned without the expressed written permission from BeaconMedaes Engineering.		Scale: D	
Description: GENERAL ASSEMBLY 15HP PX-EXP-HX CLAW VSD VAC SPC 240G RECEIVER		Part Number: 4107 8549 73	
DN: HOP230420		Rev: 03	
Sheet 1 of 1		DO NOT SCALE THIS DOCUMENT	