



Notes:

- 1. DISCHARGE MUFFLERS WILL BE SHIPPED LOOSE.
- 2. SYSTEM WEIGHT: 5,175 LBS.
- 3.  INDICATES LIFTING POINT.
- 4.  DENOTES CENTER OF GRAVITY.

SYSTEM CONNECTIONS	
ID	DESCRIPTION
I	INLET LOCATION
D	DISCHARGE LOCATION
C	CONDENSATE DRAIN LOCATION
T	TANK DRAIN LOCATION

MINIMUM CLEARANCE FOR
MAINTENANCE & VENTILATION

Ø0.75 BOLTDOWNS
(12 PLACES)

ELECTRICAL
CONNECTION

AIR PURGE
INLET FILTER
PER PUMP

PUMP ISOLATION VALVE
WITH 24V ACTUATOR
PER PUMP

200 GALLON
RECEIVER

INTAKE FILTER
PER PUMP


DISCHARGE
2" FLANGE
(2 PLACES)

RECEIVER
BYPASS
VALVE

INLET
3" FLANGE

CONTROL CABINET

MANUAL
CONDENSATE
DRAIN, TYP

Revised: MDB	Date: 06/19/2019	Drawn: MDB	Date: 11/10/2017
		Scale: D	
Description: GENERAL ASSEMBLY 8.7HP QX LAB VSD CLAW VAC SPC 200G RECEIVER STANDARD & O2 ASSURED		Part Number: 4107 8562 72	
DN: BM190348		Rev: 01	
Sheet 1 of 1		DO NOT SCALE THIS DOCUMENT	