



DESICCANT AIR DRYER SOLENOID VALVE ASM
(LOCATED ON SIDE OF CONTROL PANEL LEG)

—	AIR LINE
.....	DRAIN LINE
- - - - -	INSTRUMENT LINE
▶	PNEUMATIC FLOW
◀	CONDENSATE FLOW

INSTRUMENTATION DETAILS			
SENSOR	DESCRIPTION	SETTING	ACTION
S1	HIGH DISCH TEMP	10HP-465°F 15HP-465°F	SHUTDOWN
S2	PRESS TRANSDUCER	0-145PSI	OPERATION
S3	BACKUP PRESS SW.	CUT IN-110PSI CUT OUT-135PSI	BACKUP OPERATION
S4	DP SENSOR	-30° C	ALARM

Revised: SMB	Date: 11/19/2019	Drawn: SMB	Date: 08/12/2019
		Scale: NTS	
Description: DWG PNEU QX SCRL LAB 10-15HP 10BAR -40		Part Number: 4107 8570 31	
Sheet 1 of 1		DNE: HOP191299 Rev: 03 DO NOT SCALE THIS DOCUMENT	