



- NOTES:
1. ALL INTERCONNECTING PIPE AND FITTINGS SHALL BE INSTALLED BY THE CONTRACTOR.
 2. ALL PIPING SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 99. PIPING LAYOUT IS DIAGRAMMATIC ONLY. FINAL ARRANGEMENT WILL BE SITE SPECIFIC. CONTRACTOR WILL BE RESPONSIBLE FOR FIELD VERIFICATION AND COORDINATING ACTUAL LOCATION WITH ALL OTHER TRADES.
 3. CONTRACTOR SHALL VERIFY MOTOR VOLTAGE, PHASE, AND AMP RATINGS BEFORE STARTING ELECTRICAL INSTALLATION; AND MAKE CERTAIN THE VOLTAGE SUPPLIED BY THE HOSPITAL IS THE SAME.
 4. THE ROOM REQUIRES DEDICATED MECHANICAL VENTILATION WITH AN ALLOWABLE TEMPERATURE VARIANCE OF 40° TO 105°F. (FOR HIGHER AMBIENTS, CONSULT FACTORY)
 5. ELECTRICAL POWER SHALL BE SUPPLIED FROM THE EQUIPMENT SYSTEM BRANCH OF THE ESSENTIAL ELECTRICAL SYSTEM (EMERGENCY POWER).
 6. EQUIPMENT, INSTALLATION, AND TESTING OF THE MEDICAL VACUUM SYSTEM SHALL COMPLY WITH NFPA 99, AND ALL STATE AND LOCAL CODES OR ORDINANCES.
 7. WIRE LAG & HIGH TEMP. ALARM REMOTE CONTACTS IN THIS CONTROL SYSTEM TO MASTER ALARM SYSTEM AS REQUIRED BY NFPA 99.
 8. ALL ACCESSORIES, PIPE, AND FITTINGS, EXCEPT DISCHARGE FLEX HOSES, BEYOND INLET AND DISCHARGE PORTS ARE SUPPLIED AND INSTALLED BY OTHERS.
 9. WHEN DETERMINING THE TOTAL PIPE LENGTH, ADD ALL THE STRAIGHT LENGTHS OF PIPE TOGETHER IN ADDITION TO THE NUMBER OF ELBOWS TIMES THE EFFECTIVE PIPE LENGTH FOR THAT PIPE SIZE. (SEE EQUIVALENT PIPE LENGTH TABLE BELOW.)

EXHAUST PIPE SIZE TABLE (SEE NOTE 9)			
UNIT SIZE	PIPE LENGTH		
	0' - 250'	251' - 500'	
1.5 HP	1.25" NPT	1.5" NPT	
UNIT SIZE	PIPE LENGTH		
	0' - 250'	251' - 500'	
2 HP	1.5" NPT	2.0" NPT	
UNIT SIZE	PIPE LENGTH		
	0' - 100'	101' - 400'	401' - 500'
3 HP	1.5" NPT	2.0" NPT	3.0" NPT
UNIT SIZE	PIPE LENGTH		
	0' - 150'	151' - 500'	
5 HP	2.0" NPT	3.0" NPT	

EFFECTIVE PIPE LENGTH TABLE FOR ELBOWS				
PIPE SIZE (IN)	1.25" NPT	1.5" NPT	2.0" NPT	3.0" NPT
EFFECTIVE PIPE LENGTH (FT)	3.4	4.0	4.9	7.9

Revised: APS	Date: 3/2/2023	Drawn: JEB	Date: 4/29/2011
		Scale: D	
Description: INSTALLATION DIAGRAM TANK MOUNT LUBE VAC 1.5-5HP DX		Part Number: 4107 8530 98	
DN: HOP230842		Rev: 04	
Sheet 1 of 1		DO NOT SCALE THIS DOCUMENT	