

# **Signal Amplifier**

Zeus Medical Gas Alarm Systems
Operation and Maintenance Manual







Published by Pneumatech Medical Gas Solutions

All possible care has been taken in the preparation of this publication, but Pneumatech Medical Gas Solutions accepts no liability for any inaccuracies that may be found.

Pneumatech Medical Gas Solutions reserves the right to make changes without notice both to this publication and to the product which it describes.

Copyright © 2015 Atlas Copco All rights reserved.

No part of this publication may be reproduced, transmitted, transcribed, or stored in a retrieval system or translated into any human or computer language in any form or by any means without the prior permission of Pneumatech Medical Gas Solutions.



#### Important

Personnel must make themselves familiar with the contents of this manual and the function of the unit before installing, operating or maintaining any Zeus 15 Serial Signal Amplifier.

Information contained in this manual is correct at the date of publication. The policy of Pneumatech Medical Gas Solutions is one of continuous product improvement. Pneumatech Medical Gas Solutions reserves the right to make changes that may affect instructions in this manual without prior notice.

For any enquiry regarding the servicing or repair of this device, contact the nearest accredited Pneumatech Medical Gas Solutions agent, or communicate directly with:



Pneumatech Medical Gas Solutions Unit 18 Nuffield Centrum Nuffield Way Abingdon Oxfordshire OX14 1RL UK

http://www.p-mgs.com

Sales Spares Service

Tel: 44 (0) 1235 463010 Tel: 44 (0) 1235 463053 Tel: 44 (0) 1235 463051 Fax: 44 (0) 1235 463011 Fax: 44 (0) 1235 463011 Fax: 44 (0) 1235 463011 sales@p-mgs.com spares@p-mgs.com service@p-mgs.com

Any complaints about the products or services provided by Pneumatech Medical Gas Solutions, please give as much of the following information as possible:

Product Part Number Lot/ Batch Number Approximate date of purchase Apparent fault.

Complaints

T: 44 (0) 1235 463010 F: 44 (0) 1235 463011 complaints@p-mgs.com



# Table of Contents

Λ	SAFETY	<b>STORAGE</b>		HANDI	ING
U.	SAFELY.	SIUMAGE	AINU	HAINUL	มเทษ

- 0.1 Symbols
- 0.2 Environmental Conditions
- 0.3 Cleaning
- 0.4 Environmental Protection
- 0.5 Electromagnetic Interference
- 0.6 Electrical Details
- 1. DESCRIPTION AND OPERATION
- 1.1 Introduction
- 1.2 Configuration
- 1.3 LED Status Indicators
- 2. INSTALLATION
- 2.1 Power Supply
- 2.2 Location
- 2.3 Fitting
- 2.4 Connections
- 3. MAINTENANCE
- 4. RECOMMENDED SPARES
- 5. WIRING DIAGRAMS

# SAFETY, STORAGE AND HAN-DLING

# 0.1 Symbols

3

3

3

3

4

4

4

4

4

4

4

4

4

4

5

5

5

5

The following symbols apply to this product and are used in these instructions and on the product in question. The meanings of these symbols are as specified below: -

i	Read instructions	
4	Warning - dangerous voltage	
1	Ambient temperature range	
<u></u>	Ambient humidity range	
<b>9.0</b>	Ambient pressure range	
	Date of manufacture	
<u> </u>	Caution - system alarm	
<u>ပ</u>	Power on	
<b>#</b> /s	Mute switch	
<७>>	Test lights	
4	Protective earth	
	Alternating current	

## 0.2 Environmental Conditions

Min ambient temperature - 0 degrees Celsius Max ambient temperature - 40 degrees Celsius Min relative humidity (non-condensing) - 10% Max relative humidity (non-condensing) - 95% Atmospheric pressure range - 70-110 kPa

# 0.3 Cleaning

The alarm cover and fascia should be wiped over with a damp cloth frequently to remove any dust or foreign substances.

#### 0.4 Environmental Protection

Discard the unit and/or components in line with WEEE regulations, or other local applicable regulations.



# 0.5 Electromagnetic Interference

Ensure any input and data cables are physically separated from other mains and data cables.

#### 0.6 Electrical Details

WARNING... It is necessary to check the integrity of the power source for safety at regular intervals. These checks should be carried out annually and replacement power supplies used is necessary.

#### Power source:

Mains operated using 85.5 - 264V, at 48 - 62 Hz, alternating current, from an essential circuit.

# Current requirements:

3.0 amps

Type of protection against electric shock:

Class 1 (Mains supplied equipment using a protected earth)

#### Mode of operation:

Continuous (equipment may be left switched on indefinitely)

Degree of protection against ingress of liquids: IPX0 (Not protected)

#### Degree of mobility:

Permanently installed (This unit is electrically connected by permanent means)

#### Degree of protection:

Type B (no Applied Part or with and Applied Part not designed to meet F type (floating) requirements)

Degree of protection against flammable anaesthetic mixtures:

Not protected (not suitable for use with flammable gases)

# 1. DESCRIPTION AND OPERATION

#### 1.1 Introduction

The Penlon MGS Zeus 15 Serial SIgnal Amplifier provides a means to boost the RS-485 data signal of the Zeus 15 alarm system. The standard maximum length of a data cable segment is 1200 metres. Using a serial signal Amplifier allows for two cable segments, each up to 1200 metres.

In addition, the Penlon MGS Zeus 15 Serial SIgnal Amplifier allows non-standard network topologies, for example with branches, to be built.

The Penlon MGS Zeus 15 Serial SIgnal Amplifier is sup-

plied in an IP67 rated enclosure, so can be installed outside if needed.

TABLE 1: Zeus 15 Signal Amplifier Dimensions

Height(mm)	200
Length(mm)	200
Depth(mm)	180

# 1.2 Configuration

The Westermo RD-48 at the heart of the Penlon MGS Zeus 15 Serial SIgnal Amplifier is pre-configured at the factory. If difficulties are encountered, the DIP switch settings should be checked. Locations of the DIP switches are discussed in the manual for the Westermo RD-48, enclosed with the serial signal Amplifier.

Switch	Setting	
SW1	OFF, OFF, ON, OFF, ON, OFF	
SW2	ON, ON, ON, ON	
SW3	OFF, OFF, OFF, ON, ON, ON	
SW4	OFF, OFF, OFF, ON, ON, ON	

TABLE 2: Signal Amplifier Configuration

NB Depending upon exact installation, the settings of SW3 and SW4 may change from those defined above. For more information, check the manual for the Westermo RD-48 enclosed with the signal Amplifier.

#### 1.3 LED Status Indicators

The Westermo RD-48 is equipped with a series of diagnostic LEDs to aid in fault finding. For more details on these, refer to the manual for the Westermo RD-48.

### 2. INSTALLATION

#### 2.1 Power Supply

The Penlon MGS Zeus 15 Serial Signal Amplifier requires a double-pole switched fused connection unit, fitted with a three amp fuse.

#### 2.2 Location

The Penlon MGS Zeus 15 Serial Signal Amplifier can be fitted in any suitable location, for example in plant rooms, risers and ceiling voids.

# 2.3 Fitting

The Penlon MGS Zeus 15 Serial Signal Amplifier comes with a fixing kit that suits most installations. Mark out fixing



points and secure the serial signal Amplifier to a suitable mounting surface.

#### 2.4 Connections

The cable segments should be connected to the LINE A and LINE B connections, with the "A" wire connecting to the T- terminal, and the "B" wire connecting to the T+ terminal

The R+ and R- terminals are not used.

Ensure that all panels on both network segments are powered down during installation to prevent short circuits.

# 3. MAINTENANCE

The Serial Signal Amplifier requires no specific maintenance, and should provide years of service with little or no intervention.

Should spares be required, please contact the Staveley Office for pre-configured parts.

Figure 1. Simple Signal Amplifier

# 4. RECOMMENDED SPARES

Westermo RD-48 HV Repeater Part No. 6000177

# 5. WIRING DIAGRAMS

The following pages illustrate the possibilities for wiring the serial signal Amplifier.

In addition to boosting the signal for longer runs, it also allows non-standard cable topologies (such as T's and stars) to be produced.




Figure 2. Star Structure






Figure 3. Single branch structure





Figure 4. Double branch structure





Pneumatech Medical Gas Solutions Unit 18 Nuffield Way Abingdon Oxfordshire

OX14 1RL UK
Sales Spares

T: 44 (0) 1235 463010 T: 44 (0) 1235 463053 F: 44 (0) 1235 463011 F: 44 (0) 1235 463011 sales@p-nmgs.com spares@p-mgs.com

Document 8102341081 Ref. 01 12/10/2015 © Pneumatech Medical Gas Solutions 2015. All rights reserved.

Service

T: 44 (0) 1235 463051 F: 44 (0) 1235 463011 service@p-mgs.com













